

CITY OF BALTIMORE WET WEATHER CONSENT DECREE SMOKE AND
DYED WATER TESTING FORM

Page 1 of 2

Sewershed: Dundalk

Consultant: RJN Group, Inc.

Date: YYYYMMDD
2008109109

Test to be performed:
Smoke ☒ Dye ☐

Ground Condition:
☒ Dry ☐ Damp ☐ Wet


Supervisor initials: TS

Manhole ID: S 65E - 009 MH

Test ID: 1047- 150

Notifications - made daily: ☒
(Residents, Fire, 311)

Field Sketch: Show all manholes with numbers, blower placement location, sandbag or isolation device location, street names, building addresses and locations, defect locations and photograph numbers.



**CITY OF BALTIMORE WET WEATHER CONSENT DECREE SMOKE AND
DYED WATER TESTING FORM**

Page 1 of 2

Sewershed: Dundalk

Consultant: RJN Group, Inc.

Date: YYYYMMDD
2008 10 09

Test to be performed:
Smoke / Dye

Ground Condition:
Dry Damp Wet

Supervisor initials: TS

Manhole ID: S 65E - 009 MH

Test ID: 1047- 150

Notifications - made daily: ✓
(Residents, Fire, 311)



S1047-150-OB01 -P01 Downspouts, heavy smoke.



S1047-150-OB02-P01 Downspouts, heavy smoke.



S1047-150-OB03-P01 Private Lateral medium smoke, concrete.